



GENERAC GENERATOR PREVENTIVE MAINTENANCE SERVICE AGREEMENT

Date: _____

CUSTOMER NAME: _____

CUSTOMER ADDRESS: _____

CUSTOMER ADDRESS: _____

CUSTOMER PHONE: _____ CELL: _____

GENERATOR E-MAIL: _____

GENERATOR MODEL: _____ . SERIAL #: _____

PRICE

Annual Maintenance Agreement..... **\$289.00**

*Includes 24/7 generator monitoring (generator must be connected to wifi, Generator must be serviced every year to be included in 24/7 monitoring) Cost is \$250 without 24/7 generator monitoring.

Annual agreement includes one scheduled maintenance visit every year. Includes 24/7 generator monitoring (See attached Preventative Maintenance Schedule for details) Customer is entitled to a 15% discount on any generator repairs and standard labor rates. I accept and agree to the maintenance agreement term selected above as detailed on page 2 of this agreement

Customer Acceptance Signature: _____ Date: _____

Mail a copy of the agreement along with payment to : Reliable Energy of NJ
417 Ocean Rd
Spring Lake, NJ 07762
E-MAIL: david@reliableenergynj.com

TERMS: Reliable Energy of NJ (RENJ) agrees to provide the maintenance services described on page 2 for the period commencing upon payment of the charges set forth above and continuing for the one year Term selected by Customer. This Agreement will renew automatically for additional terms of one year each unless terminated by written notice at least 30 days prior to the end of the then current Term. This Agreement covers only the routine maintenance services specified on page 2. All required Parts and additional labor not covered by Manufacturer's warranty will be supplied at additional cost. All work will comply with manufacturer's guidelines and be performed in a professional manner and RENJ agrees to correct any non-conforming services provided hereunder promptly. RENJ disclaims all other warranties, express or implied. Customer agrees that in no event shall RENJ be liable for indirect, consequential, special, exemplary or incidental damages of any kind arising out of this Agreement.



PREVENTATIVE MAINTENANCE SCHEDULE

I – Inspect, C – Clean, R – Replace

	Annual Maintenance FUEL
Fuel Lines and connections	I
Flexible Fuel Line	I
LUBRICATION	
Oil Level	I
Oil (5w - 30 synthetic) - Every 200 Hours or Annually	R Oil Filter -
Every 200 Hours or Annually	R
COOLING	
Enclosure louvers	I/C
GENERAL CONDITION	
Vibration, noise, leakage, temp	I
BATTERY	
Remove corrosion, ensure dryness	I/C
Clean and tighten battery terminals	I/C
Check charge state	I
Electrolyte level***	I/R
BATTERY CABLE	
Remove corrosion, clean & tighten	I/C
OUTSIDE ENCLOSURE	
Apply conditioner and wax	C
ENGINE AND MOUNTING	
Air cleaner***	R
Spark plugs(s)***	R
Apply corrosion inhibiting spray to engine parts	C
EXTERNAL CONNECTION BOX	
Tighten terminals	I
Check for proper operation	I
Check control wiring connection	I
ELECTRICAL SYSTEMS	
No load output voltage	
Line to line - 240volts	I
Line to neutral - 120volts	I
Line to ground - 120volts	I
Grounding conductor	I
Earth ground	I
DC control fuse	I
Battery charger fuse	I
Auto/off/manual switch	I
Levelness of generator	I

*** Replace as necessary